



800 NE Oregon Street, Suite 465, Portland OR 97232

Voice: (971) 673-0540

Fax: (971) 673-0556

TTY: (971) 673-0372

Facilities Planning & Safety Unit

http://www.healthoregon.org/fps

mailbox.fps@state.or.us

Site Inspection Check List for:

Rehabilitation Therapy Department - OAR 333-535-0130

PR# _____ Date: _____ Inspector: _____

Provider: _____

Project: _____

Address: _____

Present at Site Inspection: _____

Intended Occupancy Date: _____

Required PRIOR to Approved Inspection:

RECEIVED?

YES NO NA

Certificate of Occupancy (CO) from governing jurisdiction

MEP Close-Out verification (if required)

SITE INSPECTION:

INTERIOR = Verify that the facility has installed:

OVERALL:

YES NO NA

If a formal Rehabilitation Therapy Service is provided, facilities and equipment shall be required for the effective function of the program. 333-535-0130 (1)

Where two or more Rehabilitative Services are included, items may be shared between service elements, in accordance with the functional Program. 333-535-0130 (1)

- The Rehabilitation Therapy Department shall include the following, which may be shared or provided as separate units for each service, in accordance with the Function Program: 333-535-0130 (2)
- Office space with provision for filing and retrieval of patient records. 333-535-0130 (2)(a)
- Patient waiting space with provisions for wheelchairs out of traffic. 333-535-0130 (2)(b)
- Treatment area(s) as programmed for thermo-therapy, diathermy, ultrasonic and hydrotherapy. 333-535-0130 (2)(c)
- Cubicle curtains shall be provided around each individual treatment area. 333-535-0130 (2)(c)
- Hand-washing stations shall be provided at a rate of 1 per 4 treatment spaces. 333-535-0130 (2)(c)
- Facilities for collection of wet and soiled linen and other materials shall be provided 333-535-0130 (2)(c)
- Exercise Area 333-535-0130 (2)(d)
- Storage for clean linen, supplies and equipment 333-535-0130 (2)(e)
- Patient dressing areas and toilet rooms with hand -washing stations accessible to wheelchair patients. 333-535-0130 (2)(f)
- A conveniently accessible housekeeping closet and service sink. 333-535-0130 (2)(g)
- Wheelchair & stretcher storage shall be provided out of traffic and treatment space areas, but shall be conveniently located. 333-535-0130 (2)(h)
- Secure storage shall be available to the department for staff personal property 333-535-0130 (2)(i)

Convenient access to toilet rooms shall be provided. 333-535-0130 (2)(j)